

October 27, 2024  
 Ref.: 317912

To: All Tender Participants

Dear Sir / Madam,

**Re: Public Tender No. PD23000453 (the “Tender”) – Clarifications**

The Company has received certain requests for clarification regarding the Tender, in accordance with Section 5.1 thereof, provided below (the “Questions”). Next to each Question is the Company’s answer, which shall be considered by the Company as authoritative.

		<b><u>Question</u></b>	<b><u>Answer</u></b>
1	Technical	Confirmation of Manufacturer in India	Not accept
2	Technical	The new pump (P30) shall be installed parallel to an existing two vertical pumps P10 & P20. <u>The new pump (P30) shall be identified to the existing pumps.</u> Attached are drawings of the existing pumps as well as pumps performance diagrams – <b>Attachments A</b>	See attached
3	Technical	In the SPECIFICATION FOR VERTICAL CENTRIFUGAL PUMP - As per clause 4, Trillium will be quoting API 11 <sup>th</sup> ed pumps in lieu of the specified API 12 <sup>th</sup> ed. Please confirm.	Not accept
4	Technical	In the SPECIFICATION FOR VERTICAL CENTRIFUGAL PUMP - As per clause 5.6 – Plan 13 is recommended for quoted vertical pumps.	Accept 12 Plan
6	Technical	In the pump Datasheet - Inspection on welds – Magnetic particle testing shall be offered for all the welds.	Confirmed
7	Technical	Please provide the Attachments A, B, C and D mentioned in pump specifications.	See attached
8	Technical	Kindly advise whether NEMA motors will be acceptable in lieu of IEC motors. NEMA motors will be competitive since this design incorporates thrust bearings in the motor and there is no separated thrust pot or thrust stand in the pump.	Not accept
8	Submission Deadline:	Extend the Submission Deadline to November 12, 2024 (the “ <b>Extended Deadline</b> ”).	Accept



Thank you for your continued interest in the Tender; we look forward to receiving your bids.

Sincerely,



Eran Rheinisch

Procurement and Engagements Department

