

September 4, 2024
Ref.: 316643

To: All Tender Participants
Dear Sir / Madam,

Re: Public Tender No. PD24001208 (the "Tender") – Clarification #1

The Company has received certain requests for clarification regarding the Tender, in accordance with Section 5.1 thereof, provided below (the "Questions"). Next to each Question is the Company's answer, which shall be considered by the Company as authoritative.

		<u>Question</u>	<u>Answer</u>
1	Technical	Please advise type and properties of the foam concentrate	See below

Propriétés du produit Product Properties		Results	Specifications	Unit	Standard
pH / pH-Value		7.0	6.0 – 9.5		EN 1568
Viscosity Sp3, 30rpm / Viscosité		2100	1300 - 2500	cP	
Density / Densité		1.03	1.02 – 1.04	g/ml	EN 1568
Refractive Index / Indice de réfraction		1.352	NA		
Surface Tension / Tension superficielle 3% Solution at 20°C		16.7	≤ 17.5	mN/m	EN 1568
Quality of Foam / Qualité de l'émulseur		Concentration d'utilisation Usage Concentration	3	%	
Potable Water / Eau potable	Expansion Ratio Taux de foisonnement	9.0	≥ 5.4		EN 1568-3
low Exp / Bas foisonnement	25% Drainage Time Temps de décantation	361	≥ 360	s	EN 1568-3
Analysis Conclusion / Conclusion de l'Analyse		Pass*	Pass / Fail		

Thank you for your continued interest in the Tender; we look forward to receiving your bids.

Sincerely,



Eran Rheinisch

Procurement and Engagements Department

