

January 12, 2025
 Ref.: 320757

To: All Tender Participants

Dear Sir / Madam,

Re: Public Tender No. PD24000023/ (the "Tender") – Clarification

The Company has received certain requests for clarification regarding the Tender, in accordance with Section 5.1 thereof, provided below (the "**Questions**"). Next to each Question is the Company's answer, which shall be considered by the Company as authoritative.

		<u>Question</u>	<u>Answer</u>
1	Technical	Par. 5.2 in the technical requires ATEX zone1 for the exhaust of the diesel engine. Par 5.4 requires IP65 for the control panel. What about other components of the engine like battery alternator and starter, does the whole diesel engine has to comply with the ATEX?	For other pump components (i.e. junction boxes, control panel etc.), Zone 2 is satisfactory

Thank you for your continued interest in the Tender; we look forward to receiving your bids.

Sincerely,



Eran Rheinisch

Procurement and Engagements Department

