

December 8, 2024  
 Ref.: 319534

To: All Tender Participants

Dear Sir / Madam,

**Re: Public Tender No. PD24001422/ (the “Tender”) – Clarification #1**

The Company has received certain requests for clarification regarding the Tender, in accordance with Section 5.1 thereof, provided below (the “**Questions**”). Next to each Question is the Company’s answer, which shall be considered by the Company as authoritative.

		<u>Question</u>	<u>Answer</u>
1	Technical	please kindly clarify if these are <b>butterfly valves</b> . "for on/off (isolation) or control application if these are for control function then need to receive process conditions, application description and project requirements	Butterfly valves are On/Off and not control valves.
1	Technical	Regarding Public Tender No. PD24001422 we couldn't find Annex G (the “Technical Specifications”) in tender documents.	For now, we don't have technical specification. In the bill of quantities is mention the technical specification.
1	Technical	Which UL/FM approval is specifically required? Are we talking about Fire Water?	Butterfly valves – Wafer type.
1	Technical	Are we talking about Fire Water? If not, which is the flow media and the application that these valves are required for? Are these valves required as Wafer, or Lug, or Double Flanged?	Gate valves - Flanged

Thank you for your continued interest in the Tender; we look forward to receiving your bids.

Sincerely,



Eran Rheinisch

Procurement and Engagements Department

